

DESIGN AND SIMULATION ANALYSIS OF OUTPUT SYSTEM FOR TRI-FREQUENCY GYROTRON

Debasish Mondal¹, Ravinder Beemagani¹, S. Yuvaraj², A. K. Jha¹, and M. V. Kartikeyan^{3,4}

¹Department of Electrical Engineering, IIT Tirupati, India

²Department of Electronics and Communication Engineering, NIT Andhra Pradesh, India

³Department of Electronics and Communication Engineering, IIT Roorkee, India

⁴Indian Institute of Information Technology, Design and Manufacturing, Kancheepuram, India

ABSTRACT

The design and optimization of a comprehensive output system for tri-frequency conventional cavity gyrotron, operating at 42 GHz (TE_{6,2} mode), 84 GHz (TE_{10,4} mode), and 95 GHz (TE_{12,4} mode), is explored in this study [1]. The design of essential components such as the nonlinear taper (NLT), quasi-optical launcher (QOL), sapphire Brewster window, and matching optics unit (MOU) are carried out. The NLT and QOL designs tailored to support each frequency are developed using our in-house code Gyrotron Design Suite (GDS-2018), ensuring precise optimization [2]. A pivotal aspect of the system is the efficient conversion of the higher-order mode RF wave into a near-Gaussian profile suitable for propagation [3]. To achieve this, a dimpled-wall QOL design is employed, and optimized using a combination of GDS-2018 and commercial code package of Launcher Optimization Tool (LOT) [2], [4]. The Gaussian content factors exceeding 99.68%, 99.85%, and 99.91% for the tri-frequency gyrotron operating at 42 GHz, 84 GHz, and 95 GHz, respectively, are obtained by simulations. Further, a common sapphire Brewster window for the tri-frequency gyrotrons, strategically designed to facilitate the efficient transport of the near-Gaussian beam towards the tokamak core [3]. The final output component comprises an MOU (consisting of two beam shaping mirrors) system post-RF window to employ synthetic Gaussian beam to ensure optimal beam quality and efficient coupling to the corrugated waveguide [5], [6]. Parameters such as beam ellipticity and astigmatism are evaluated to estimate effective beam propagation while maintaining beam quality.

References

- [1] G. S. BAGHEL and M. V. KARTIKEYAN, *IEEE Trans. Electron Devices*, 65(4) (2018), p. 1558–1563, doi: 10.1109/ted.2018.2808380.
- [2] S. YUVARAJ, G. S. BAGHEL, S. SINGH, and M. V. KARTIKEYAN, *Private Commun., Indian Inst. Technol. Roorkee, Roorkee, (India, Internal Rep., 2018)*.
- [3] M. V. KARTIKEYAN, E. BORIE, and M. THUMM, (Springer-Verlag, Berlin, Germany, 2004).
- [4] J. NEILSON, in *Infr. Millim. Waves, Conf. Dig. Joint 29th Int. Conf., 12th Int. Conf. Terahertz Electron.*, 2004, p. 667-668, doi: 10.1109/ICIMW.2004.1422267.
- [5] D. MONDAL, S. YUVARAJ, M. RAWAT, M. K. A. THUMM, and M. V. KARTIKEYAN, *IEEE Trans. on Plasma Sci.*, (2024), p.1-8, doi: 10.1109/TPS.2024.3357837.
- [6] J. JIN, G. GANTENBEIN, J. JELONNEK, M. THUMM, and T. RZESNICKI, *IEEE Trans. Plasma Sci.*, 42(5) (2014), p. 1380–1384, doi: 10.1109/tps.2014.2310903.